

**SIERRA COUNTY**

**Department of Public Works and Transportation**

P. O. Box 98

Downieville, California 95936

(530) 289-3201 FAX (530) 289-2828



**Tim H. Beals**  
Director

July 30, 2010

TO: Planholders

FR: Bryan Davey  
Project Manager

RE: Addendum 2 Yuba Theatre Improvements

Attached please find Addendum 2 prepared by James Crippen Architect for the Yuba Theatre Improvements. These Addenda will be posted on the county website.

Please be reminded that acknowledgement of receipt of Addenda is required for bids to be considered Responsible and Responsive. Acknowledgement is to be made on form provided on Page 20 of the Bidding Documents, Specifications and Contract Documents.

BRDmbd721

# James Crippen Architect

1005 Terminal Way, Suite 140, Reno, NV 89502 (775) 322-2228

## ADDENDUM TO DOCUMENTS

Addendum 2

### YUBA THEATER

JULY 30, 2009- 2010

#### THE FOLLOWING ITEMS AND CLARIFICATIONS:

- 1) Building waste piping; The existing waste line below the toilet rooms and exiting the building to be replaced with new DWV piping (Sched 40) to the exterior wall of the building. Install a new sleeve in the existing wall opening for exterior piping and seal gaps between pipe and sleeve. See septic replacement plans for exterior piping.